

COMMONWEALTH OF KENTUCKY  
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF REIDLAND WATER	)	
AND SEWER DISTRICT FOR A DEVIATION	)	
FROM 807 KAR 5:066, SECTION 5(4)	)	CASE NO. 89-121
REGARDING WATER STORAGE	)	

O R D E R

By application received May 10, 1989, Reidland Water and Sewer District ("Reidland Water") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to ensure a minimum of 1 day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Reidland Water's current water storage capacity is 687,000 gallons.
2. Reidland Water's average daily water usage is 700,000 gallons.
3. Reidland Water produces its own water.
4. Reidland Water's current water storage facilities are not deemed adequate and are therefore not in compliance with 807 KAR 5:066, Section 5(4).
5. Reidland Water is in the planning stages on improvement projects for its water distribution system. One of those projects includes the construction of a 500,000-gallon water storage tank.

6. Because of the time needed to plan, finance and implement a program to construct water storage facilities, Reidland Water should be given until June 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:

1. Reidland Water be and it hereby is given until June 1, 1992 to comply with the provisions of 807 KAR 5:066, Section 5(4).

2. Reidland Water shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to June 1, 1992.

Done at Frankfort, Kentucky, this 16th day of June, 1989.

PUBLIC SERVICE COMMISSION

  
Chairman

  
Vice Chairman

  
Commissioner

ATTEST:

\_\_\_\_\_  
Executive Director